



OVERHEAD SERVICE CONDUCTOR PROVIDED AND INSTALLED BY ELECTRIC DEPARTMENT

CUSTOMER TO HAVE NO LESS THAN 36" OF SERVICE WIRE OUT OF WEATHERHEAD FOR SERVICE CONNECTION BY ELECTRIC DEPARTMENT.

MAST GUYING TO BE PROVIDED AND INSTALLED BY CUSTOMER IF REQUIRED BY ELECTRIC DEPARTMENT

DEADEND CLAMP PROVIDED AND INSTALLED BY CUSTOMER

MAST, WEATHERHEAD AND SERVICE WIRE PROVIDED AND INSTALLED BY CUSTOMER

1 1/4" CONDUIT PROVIDED AND INSTALLED BY CUSTOMER

APPROX. 5'

FINAL GRADE

BAR TYPE C.T.'S OR SWITCHGEAR MOUNTED C.T.'S PROVIDED BY ELECTRIC DEPARTMENT AND INSTALLED BY CUSTOMER. WEATHERPROOF C.T. CABINET WITH HASP PROVIDED AND INSTALLED BY CUSTOMER. CUSTOMER SHALL PROVIDE ALL LUGS AND MAKE ALL CONNECTIONS IN C.T. CABINET.

METER CABINET PROVIDED BY ELECTRIC DEPARTMENT AND INSTALLED BY CUSTOMER. PROTECTIVE BARRIERS TO BE INSTALLED BY CUSTOMER IF REQUIRED BY ELECTRIC DEPARTMENT. METER LOCATION MUST BE OBTAINED FROM ELECTRIC DEPARTMENT FOR ALL NEW SERVICES AND SERVICE UPGRADES.

**TYPICAL COMMERCIAL OVERHEAD SERVICE INSTALLATION,
SINGLE METER SOCKET, SINGLE PHASE- OVER 600 AMP,
THREE PHASE- OVER 400 AMP**

IMPORTANT NUMBERS:

ELECTRIC DEPARTMENT (540) 375-3030
BUILDING INSPECTIONS (540) 375-3036
UTILITY COLLECTIONS (540) 375-3021



**City of Salem, VA
Electric Department
Service Standards**
DRAWING 5 OF 8 REVISED 02/12