



OVERHEAD SERVICE CONDUCTOR PROVIDED AND INSTALLED BY ELECTRIC DEPARTMENT

CUSTOMER TO HAVE NO LESS THAN 36" OF SERVICE WIRE OUT OF WEATHERHEAD FOR SERVICE CONNECTION BY ELECTRIC DEPARTMENT.

METER SOCKET AND HUB PROVIDED BY ELECTRIC DEPARTMENT AND INSTALLED BY CUSTOMER. PROTECTIVE BARRIERS TO BE INSTALLED BY CUSTOMER IF REQUIRED BY ELECTRIC DEPARTMENT. METER LOCATION MUST BE OBTAINED FROM ELECTRIC DEPARTMENT FOR ALL NEW SERVICES AND SERVICE UPGRADES.
 NOTE: GANG METER CENTERS NOT PROVIDED BY ELECTRIC DEPARTMENT

MAST GUYING TO BE PROVIDED AND INSTALLED BY CUSTOMER IF REQUIRED BY ELECTRIC DEPARTMENT

DEADEND CLAMP PROVIDED AND INSTALLED BY CUSTOMER

MAST, WEATHERHEAD AND SERVICE WIRE PROVIDED AND INSTALLED BY CUSTOMER

APPROX. 5'

FINAL GRADE

TYPICAL COMMERCIAL OVERHEAD SERVICE INSTALLATION, SINGLE OR GANG METER SOCKET, SINGLE PHASE- 600 AMP OR SMALLER, OR THREE PHASE- 400 AMP OR SMALLER

IMPORTANT NUMBERS:

ELECTRIC DEPARTMENT (540) 375-3030
 BUILDING INSPECTIONS (540) 375-3036
 UTILITY COLLECTIONS (540) 375-3021



City of Salem, VA
 Electric Department
 Service Standards
 DRAWING 4 OF 8 REVISED 02/12